

FORMULA & CONVERSION SHEET for DRINKING WATER TREATMENT & DISTRIBUTION

<u>CONVERSIONS</u>	<u>FLOW AND VELOCITY</u>	<u>WATER-BRAKE-MOTOR HORSEPOWER</u>
1 psi = 2.31 ft. of head 1 ft. of head = .433 psi 1 cuft of water = 7.48 gallons 1 cuft of water = 62.4 lbs. 1 gallon = 8.34 lbs. 1 gallon = 3,785 ml 1 Liter = 1,000 ml 1 Liter = 1,000 grams 1 mg/L = 8.34 lbs/MG 1 ppm = 1 mg/L 1 ml = 1 gram 1 pound = 453.6 grams 1 pound = 7,000 grains 1 kilogram = 1,000 grams 1 cuft/sec = 448.8 gpm 1 MGD = 1.55 cuft/sec 1 MGD = 694.5 gpm 1 HP = 33,000 ft.lbs./min 1 HP = .746 kilowatt 1 mile = 5,280 feet	"Q" = FLOW expressed in cubic ft per sec. (cfs) "V" = VELOCITY expressed in ft per second (fps) "A" = AREA expressed in square feet (sqft) $Q = A \times V$ $V = Q \div A$ $A = Q \div V$	$\text{WHP} = \frac{\text{GPM} \times \text{Total Head (ft)}}{3960}$ $\text{BHP} = \frac{\text{GPM} \times \text{Total Head (ft)}}{3960 \times E_p}$ $\text{MHP} = \frac{\text{GPM} \times \text{Total Head (ft)}}{3960 \times E_p \times E_m}$ <p style="text-align: center;"> E_p = Pump Efficiency (%) E_m = Motor Efficiency (%) </p>
		<u>CONVERSION OF TEMPERATURES</u>
		$^{\circ}\text{F} = (^{\circ}\text{C} \times 1.8) + 32$ $^{\circ}\text{C} = \frac{(^{\circ}\text{F} - 32)}{1.8}$ <p style="text-align: center;">Check your work: water freezes at 32°F and 0°C water boils at 212°F and 100°C</p>
<u>OBJECT</u>	<u>AREA (ft²)</u>	<u>VOLUME (ft³)</u>
Rectangle	Length' x Width'	Length' x Width' x Height'
Circle	.785 x D' x D'	
Triangle	1/2 (Base' x Altitude')	
Cylinder		.785 x D' x D' x Length'
Sphere		.5236 x D' x D' x D'
Diameter (D) = 2 x radius		Circumference = 3.14 x D
Perimeter = Sum of the Sides		
$\text{FILTRATION RATE} = \text{Flow (gpm)} \div \text{Surface Area (sqft)}$ $\text{BACKWASH RATE} = \text{Flow (gpm)} \div \text{Surface Area (sqft)}$ $\text{SURFACE OVERFLOW RATE} = \text{Flow (gpm)} \div \text{Area (sqft)}$ $\text{DETENTION TIME} = \text{Volume (gals)} \div \text{Flow (gpm)}$ $\text{WEIR OVERFLOW RATE} = \text{Flow (gpm)} \div \text{Feet of weir}$ $\text{SPECIFIC CAPACITY} = \frac{\text{Well yield (gpm)}}{\text{Drawdown (feet)}}$ $\text{FILTRATION RATE: for every 1.6 in./min. of rise or fall} = 1 \text{ gpm/ft}^2$		
$\text{Lbs. of chemical} = \frac{\text{ppm} \times 8.34 \times \text{MG}}{\% \text{ purity}}$		$\text{Specific Gravity} = \frac{\text{wt. of a particular liquid}}{\text{equivalent wt. of water}}$
$\text{ppm} = \frac{\text{lbs. of chemical} \times \% \text{ purity}}{8.34 \times \text{MG}}$		$\text{Strength of Solution} = \frac{\text{wt. of chemical}}{\text{wt. of solution}}$
$\text{Cl}_2 \text{ Dosage} = \text{Demand} + \text{Residual}$		